

CERTIFICATE

AVK GUMMI A/S, hereby certifies that our EPDM rubber compound

EUW-70

meets the following regulations:

EN 681-1	EUW-70 meets the specifications for pipe joint seals used in water and drainage applications type WA, cold potable water supply (up to 50°C)
KTW D1/D2	EUW-70 meets the specifications for drinking water applications of KTW recommendation 1.3.13, Elastomers from natural and synthetic rubber, for contact area D1 and D2 at 23°C.
W270	EUW-70 meets the specifications of W270 regarding microbial growth for large and small scale seals.
BS 6920	Rubber articles intended to come in contact with warm (60 °C) potable water.
ACS XP P 41-250, cold	EUW-70 meets the requirements of ACS XP P 41-250 for cold water.
Hydrocheck	Materials in contact with drinking water
AS/NZS 4020:2002 cold	Rubber articles intended to come in contact with cold potable water.
KIWA BRL K602	Valves and other fittings for drinking water transport and distribution systems

Yours sincerely,
AVK GUMMI A/S



Henrik Pedersen
R&D Manager

21.09.2015



Tage Bergstrøm
Quality Manager